

|   |   |  |  |  |
|---|---|--|--|--|
| <b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>   |   |  | 1. CONTRACT ID CODE<br><b>J</b>                          | PAGE OF PAGES<br><b>1</b>   <b>8</b>                         |
| 2. AMENDMENT/MODIFICATION NO.<br><b>0003</b>  | 3. EFFECTIVE DATE<br><b>28-Nov-2000</b>   | 4. REQUISITION/PURCHASE REQ. NO.<br><b>ED-99-029</b>           | 5. PROJECT NO. (If applicable)<br><b>Renaud/862-2888</b> |  |
| 6. ISSUED BY<br><b>USACE, CONTRACTING DIVISION<br/>7400 LEAKE AVE., RM 172<br/>NEW ORLEANS, LA 70118</b>  | CODE<br><b>DACW29</b>   | 7. ADMINISTERED BY (If other than Item 6)<br><b>SEE ITEM 6</b> |  | CODE   |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP code)   |   |  | (X)  | 9A. AMENDMENT OF SOLICITATION NO.<br><b>DACW29-00-B-0003</b> |
|   |   |  | X  | 9B. DATED (SEE ITEM 11)<br><b>13-Sep-2000</b>                |
|   |   |  |  | 10A. MODIFICATION OF CONTRACT/ORDER NO.                      |
|   |   |  |  | 10B. DATED (SEE ITEM 13)                                     |
| CODE  | FACILITY CODE   |  |  |  |
| <b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>  |   |  |  |  |
| <input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:<br>(a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. |   |  |  |  |
| 12. ACCOUNTING AND APPROPRIATION DATA (If required)   |   |  |  |  |
| <b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>   |   |  |  |  |
| (X)   | A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.  |  |  |  |
|   | B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO AUTHORITY OF FAR 43.103(b). |  |  |  |
|   | C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:  |  |  |  |
|   | D. OTHER (Specify type of modification and authority)   |  |  |  |
| <b>E. IMPORTANT:</b> Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.  |   |  |  |  |
| 14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)   |   |  |  |  |
| <p>The above numbered solicitation for SELA, Hollygrove Area Drainage Improvements, Pritchard Place Drainage Pump Station, Orleans Parish, Louisiana, is amended as follows:</p> <p>Changes are made to the Bidding Schedule, specifications, and drawings as shown on the attached pages.</p> <p style="text-align: center;"><b>BID OPENING DATE</b></p> <p>A Bid Opening Date of 14 December 2000, 2:00 PM local time, is hereby established.</p> <p>Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.</p>   |   |  |  |  |
| 15A. NAME AND TITLE OF SIGNER (Type or print)   |   | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)     |  |  |
|   |   | <b>CAROL J. SCHWARTZ/CONTRACTING OFFICER</b>                   |  |  |
| 15B. CONTRACTOR/OFFEROR   | 15C. DATE SIGNED  | 16B. UNITED STATES OF AMERICA                                  | 16C. DATE SIGNED   |  |
| _____<br>(Signature of person authorized to sign)   |   | BY _____<br>(Signature of Contracting Officer)                 | <b>11/21/00</b>  |  |

SECTION 00010

Pages 3, 4, & 5, Bidding Schedule. Delete the pages in their entirety and substitute the attached revised pages 3, 4, & 5, therefore.

SECTION 01100

Page 6, subparagraph 1.3.h(5). At the end of the subparagraph, replace “Demolition” with “Demobilization”.

SECTION 02231

Page 2, paragraph 1.4. Delete the first two sentences in their entirety and substitute “Measurement for granular subbase or testing will be made by the square yard. Payment will be made at the contract unit price for “Granular Subbase”.”

SECTION 02242

Page 1, paragraph 1.2. In the 3<sup>rd</sup> line, delete “Construction” at the end of the second sentence.

SECTION 02511

Page 2, paragraph 1.6.1. Delete the first two sentences in their entirety and substitute “Measurement for asphaltic concrete pavement patch and overlay will be made by the square yard. Payment will be made at the contract unit price for “Asphaltic Concrete Pavement”.”

SECTION 02512

Page 1, paragraph 1.4. Delete the first two sentences in their entirety and substitute “Measurement for granular base course will be made by the square yard. Payment will be made at the contract unit price for “Granular Base Course”.”

SECTION 02721

Page 5, paragraph 1.6. Delete the first two sentences in their entirety and substitute “Measurement for rigid base course will be made by the square yard. Payment will be made at the contract unit price for “Rigid Base Course”.”

SECTION 02754

Page 9, paragraph 1.7. Delete the first two sentences in their entirety and substitute “Measurement for concrete pavement for small projects will be made by the square yard. Payment will be made at the contract unit price for “Concrete Pavement”.”

### SECTION 02831

Page 2, paragraph 1.3. Delete the first two sentences in their entirety and substitute "Measurement for chain link fencing will be made by the linear foot. Payment will be made at the contract unit price for "Chain Link Fence"."

### SECTION 07610

Page 4, paragraph 1.7. Delete the first two sentences in their entirety and substitute "Measurement for copper roof system will be made by the square foot. Payment will be made at the contract unit price for "Copper Roof System"."

### SECTION 08120

Page 2, paragraph 1.4. Delete the first two sentences in their entirety and substitute "Measurement for aluminum doors and frames will be made by each unit. Payment will be made at the contract unit price for "Aluminum Doors and Frames"."

### SECTION 08300

Page 3, paragraph 1.8. Delete the first two sentences in their entirety and substitute "Measurement for overhead coiling door will be made by each unit. Payment will be made at the contract unit price for "Overhead Coiling Door"."

### SECTION 08600

Page 3, paragraph 1.8. Delete the first two sentences in their entirety and substitute "Measurement for exterior roll-up storm shutters will be made by each unit. Payment will be made at the contract unit price for "Exterior Roll-up Storm Shutters"."

### SECTION 10201

Page 2, paragraph 1.4. Delete the first two sentences in their entirety and substitute "Measurement for metal wall louvers will be made by each unit. Payment will be made at the contract unit price for "Metal Wall Louvers"."

### SECTION 10522

Page 1, paragraph 1.4. Delete the first two sentences in their entirety and substitute "Measurement for fire extinguishers will be made by each unit. Payment will be made at the contract unit price for "Fire Extinguishers"."

### SECTION 13110

1. Page 2, subparagraph 2.1.b. Delete this subparagraph in its entirety and substitute "b. Quantity: One 300-pound anode bed."

2. Page 2, subparagraph 2.1 . Insert new subparagraph g consisting of the following:  
“g. Junction box / test station: One junction box / test station with current measuring shunts and copper buss bar.”
3. Page 3, paragraph 3.1.1. Insert “Locate anode bed near discharge end of pipes in accordance with manufacturer’s recommendations” at the end of the paragraph.
4. Page 3, paragraph 3.1.2. Insert “Attach separate anode lead wire from each end of the three pipes (48”, 48”, and 8”), and run anode lead wires into junction box / test station. Provide test wires if required by manufacturer. Run header wire from anode bed to junction box / test station. Connect wires per manufacturer’s recommendations.” at the end of the paragraph.
5. Page 4, paragraph 3.1. Insert new paragraph 3.1.5 as follows:

“3.1.5. Junction Box / Test Station

Locate junction box / test station adjacent to east-northeast corner of concrete slab around northernmost 48” discharge pipe. Place junction box / test station flush to grade and protect with a 12” by 12” by 8” thick concrete pad.”

SECTION 15121

1. Page 1, paragraph 1.1. Insert the following reference under the AWWA section:  
“AWWA C208 (1996) Dimensions for Fabricated Steel Water Pipe Fittings”
2. Page 2, paragraph 2.2. Delete this paragraph in its entirety and substitute the following:

“2.2 FITTINGS

The fittings for the discharge pipe shall be mitered, spiral weld pipe, 48-inch OD, ½ inch wall thickness conforming to ANSI B16.9 and the applicable ASTM and AWWA standards listed above . The fittings shall be plain end with weld bead ground flush along the internal surface and at the ends. Mitered 90 elbows shall be five-piece elbows and mitered 45 elbows shall be four-piece elbows per AWWA C208. Set radius (R) and equal diameter (D).”

SECTION 15131

- Page 13, paragraph 1.11. Delete the first two sentences in their entirety and substitute “Measurement for vertical pumps will be made by each unit. Payment will be made at the contract unit price for “Vertical Pumps”.”

## SECTION 16221

Page 8, paragraph 1.5. Delete the first two sentences in their entirety and substitute "Measurement for electric motors will be made by each unit. Payment will be made at the contract unit price for "Vertical Pump Motors"."

## DRAWINGS

1. Delete Dwg.G5, 5 of 58, replace with the attached revised Dwg.G5, 5 of 58.
2. Delete Dwg.S7A, 26 of 58, replace with the attached revised Dwg.S7A, 26 of 58.
3. Delete Dwg.P1, 35 of 58, replace with the attached revised Dwg.P1, 35 of 58.

**SECTION 00010 - BIDDING SCHEDULE  
 SOUTHEAST LOUISIANA PROJECT, LOUISIANA  
 HOLLYGROVE AREA DRAINAGE IMPROVEMENTS  
 ORLEANS PARISH, LOUISIANA**

**PRITCHARD PLACE DRAINAGE PUMP STATION**

| Item  | Description  | Estimated<br>Quantity | Unit | Unit<br>Price | Estimated<br>Amount |
|-------|--|-----------------------|------|---------------|---------------------|
| 0001  | Mobilization and Demobilization                      | 01                    | LS   |               |                     |
| 0002  | Temporary Traffic Control                            | 01                    | LS   |               |                     |
| 0003  | Demolition   | 01                    | LS   |               |                     |
| 0004* | Granular Subbase                                     | 100                   | SY   |               |                     |
| 0005  | Dewatering   | 01                    | LS   |               |                     |
| 0006  | Temporary Retaining Structures                       | 01                    | LS   |               |                     |
| 0007  | Grading  | 01                    | LS   |               |                     |
| 0008  | Structural Excavation and Backfill                   | 01                    | LS   |               |                     |
| 0009  | Excavation, Trenching, and Backfilling for Site Work | 01                    | LS   |               |                     |
| 0010  | Test Pile(s)   | 2                     | Ea.  |               |                     |
| 0011* | Timber Piles - Untreated                             | 2740                  | LF   |               |                     |
| 0012* | Timber Piles - Treated                               | 3620                  | LF   |               |                     |
| 0013  | Separation/Filtration Geotextile                     | 01                    | LS   |               |                     |
| 0014  | Water Distribution System                            | 01                    | LS   |               |                     |
| 0015* | Asphaltic Concrete Pavement                          | 100                   | SY   |               |                     |
| 0016* | Granular Base Course                                 | 100                   | SY   |               |                     |
| 0017  | Sanitary Sewers                                      | 01                    | LS   |               |                     |
| 0018* | Rigid Base Course                                    | 385                   | SY   |               |                     |
| 0019* | Concrete Pavement                                    | 765                   | SY   |               |                     |

\*Denotes change from previous Bidding Schedule

SECTION 00010 - BIDDING SCHEDULE  
 SOUTHEAST LOUISIANA PROJECT, LOUISIANA  
 HOLLYGROVE AREA DRAINAGE IMPROVEMENTS  
 ORLEANS PARISH, LOUISIANA

PRITCHARD PLACE DRAINAGE PUMP STATION

| Item  | Description                     | Estimated<br>Quantity | Unit | Unit<br>Price | Estimated<br>Amount |
|-------|---------------------------------|-----------------------|------|---------------|---------------------|
| 0020* | Chain Link Fence                | 400                   | LF   |               |                     |
| 0021  | Concrete Pump Station           | 01                    | LS   |               |                     |
| 0022  | Concrete Covered Canal          | 01                    | LS   |               |                     |
| 0023  | Masonry Building                | 01                    | LS   |               |                     |
| 0024  | Structural Welding              | 01                    | LS   |               |                     |
| 0025  | Structural Steel                | 01                    | LS   |               |                     |
| 0026  | Miscellaneous Metals            | 01                    | LS   |               |                     |
| 0027  | Rough Carpentry                 | 01                    | LS   |               |                     |
| 0028* | Copper Roof System              | 2860                  | SF   |               |                     |
| 0029  | Joint Sealing                   | 01                    | LS   |               |                     |
| 0030* | Aluminum Doors and Frames       | 5                     | EA   |               |                     |
| 0031* | Overhead Coiling Door           | 01                    | EA   |               |                     |
| 0032* | Exterior Roll-up Storm Shutters | 6                     | EA   |               |                     |
| 0033  | Glass and Glazing               | 01                    | LS   |               |                     |
| 0034  | Stucco                          | 01                    | LS   |               |                     |
| 0035  | Painting                        | 01                    | LS   |               |                     |
| 0036* | Metal Wall Louvers              | 6                     | EA   |               |                     |
| 0037* | Fire Extinguishers              | 4                     | EA   |               |                     |
| 0038  | Toilet Accessories              | 01                    | LS   |               |                     |
| 0039  | In-Line Water Booster Pump      | 01                    | LS   |               |                     |
| 0040  | Oleander Canal One-Way Valve    | 01                    | LS   |               |                     |

\*Denotes change from previous Bidding Schedule

SECTION 00010 - BIDDING SCHEDULE  
 SOUTHEAST LOUISIANA PROJECT, LOUISIANA  
 HOLLYGROVE AREA DRAINAGE IMPROVEMENTS  
 ORLEANS PARISH, LOUISIANA

PRITCHARD PLACE DRAINAGE PUMP STATION

| Item   | Description   | Estimated<br>Quantity | Unit | Unit<br>Price | Estimated<br>Amount |
|--------|---|-----------------------|------|---------------|---------------------|
| 0041   | Submersible Constant<br>Duty Drain Pump                 | 01                    | LS   |               |                     |
| 0042   | Cathodic Protection                                     | 01                    | LS   |               |                     |
| 0043*  | Above-Ground Fuel<br>Storage Tank                       | 01                    | LS   |               |                     |
| 0044   | Monorails with Manual<br>Hoists and Trolleys            | 01                    | LS   |               |                     |
| 0045   | Discharge Pipes   | 01                    | LS   |               |                     |
| 0046*  | Vertical Pumps  | 2                     | EA   |               |                     |
| 0047   | Plumbing  | 01                    | LS   |               |                     |
| 0048*  | Vertical Pump Motors                                    | 2                     | EA   |               |                     |
| 0049   | Electrical Work   | 01                    | LS   |               |                     |
| 0050   | Diesel-Generator Set<br>and Auxiliary<br>Equipment      | 01                    | LS   |               |                     |
| 0051   | Asphalt Repairs to<br>Access and Haul Roads             |                       |      |               |                     |
| 0051AA | First 700 Square<br>Yards                               | 700                   | SY   |               |                     |
| 0051AB | Square Yards in<br>Excess of Quantity in<br>SLIN 0051AA | 1400                  | SY   |               |                     |
| 0052   | Heating, Ventilating,<br>and Air Conditioning           | 01                    | LS   |               |                     |
| 0053   | Fuel Storage System                                     | 01                    | LS   |               |                     |

TOTAL: \$ \_\_\_\_\_

Award will be made as a whole to one bidder.

\*Denotes change from previous Bidding Schedule