

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1   3
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 13-Jul-2004	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) POC: S. Enclade
6. ISSUED BY USACE, CONTRACTING DIVISION ATTN: CEMVN-CT, ROOM 172 7400 LEAKE AVE. NEW ORLEANS LA 70118-3651	CODE W912P8	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W912P8-04-B-0048	
		X	9B. DATED (SEE ITEM 11) 28-Jun-2004	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The above numbered solicitation for Flood Control, Amite River & Tributaries, LA, Comite River Basin, Comite River Diversion Project, Lilly Bayou Control Structure, Phase II, East Baton Rouge, LA, is hereby amended as follows:  <p style="text-align: center;">BID OPENING DATE</p> BID OPENING DATE AND TIME OF 28 JULY 2004, 2:00 P.M., LOCAL TIME AT PLACE OF BID OPENING, REMAINS UNCHANGED.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 12-Jul-2004

**SECTION 01100**

Page 01100-20. Add the following paragraphs after paragraph 20:

**“21. PRE-BID SITE VISITS**

The site will be open for pre-bid inspection by bidders on the following dates and times:

<u>DATE</u>	<u>TIME</u>
Jul 15, 2004	10:00 AM to 2:00 PM
Jul 20, 2004	10:00 AM to 2:00 PM
Jul 22, 2004	10:00 AM to 2:00 PM
Jul 26, 2004	10:00 AM to 2:00 PM

All site visits will be coordinated through:

Mr. Chester Ashley, Area Engineer  
Lafayette Area Office,  
646 Cajundome Blvd.  
Lafayette, LA 70506  
Telephone: (337) 291-3030

**22. TEST PITS**

The Contractor may excavate test pits during the periods set aside for site visits, as defined in paragraph 21. The Contractor shall notify Mr. Chester Ashley of his intent to excavate test pits at least 2 days in advance of any excavation. Proposed test pits shall be laid out by a Registered Land Surveyor and staked, and approved prior to any excavation. Test pit locations shall be restricted to the areas enclosed by the following stations and offsets and to the stated depths. All test pits shall be backfilled with the excavated material prior to the Contractor leaving the site.

(a) Upstream Test Pit Limits:

Station	Offset
3+45.0U	0+7.5L
3+45.0U	0+7.5R
0+70.0U	0+7.5L
0+70.0U	0+7.5R

Maximum depth of test pit: El. +40.0.

(b) Downstream Test Pit Limits:

Station	Offset
3+85.0D	0+40.0L
3+85.0D	0+40.0R
6+80.0D	0+40.0L
6+80.0D	0+40.0R

Maximum depth of test pit: El. +8.0.”

SECTION 15002

1. Page 15002-5, paragraph 1.6.2.2. Line 2, delete “and coarse” and change “aggregates” to “aggregate”.
2. Page 15002-6, paragraph 1.8. Lines 3 and 5, change “CLSM fill” to “CLSM”.
3. Page 15002-9, paragraph 2.1.3.2.5. Line 1, change “CLSM fill” to “CLSM”. Line 7, change “ASTM C 39, and (e)” to “ASTM C39, (e)”. Line 8, delete “during pumping.” and substitute “during pumping, and (f) have an air content of 17 percent with a tolerance of (+/-) 1.5 percent.”
4. Page 15002-10, paragraph 2.2.1. Delete this paragraph in its entirety.
5. Page 15002-10, paragraph 2.2.2. Line 4, delete “either” and “or ASTM C 685”.
6. Page 15002-12, paragraph 3.4.1.2. Lines 1 and 4, change “CLSM fill” to “CLSM”.
7. Page 15002-13, paragraph 3.4.1.3. Line 1, delete “for each class of concrete required”.