

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J	PAGE OF PAGES 1 2
2. AMENDMENT/MODIFICATION NO. 0003	3. EFFECTIVE DATE 03-Feb-2006	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)	
6. ISSUED BY USACE, CONTRACTING DIVISION ATTN: CEMVN-CT, ROOM 172 7400 LEAKE AVE. NEW ORLEANS LA 70118-3651	CODE W912P8	7. ADMINISTERED BY (If other than item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X	9A. AMENDMENT OF SOLICITATION NO. W912P8-06-R-0086
				X	9B. DATED (SEE ITEM 11) 06-Jan-2006
					10A. MOD. OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS			
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The above numbered solicitation for Lake Pontchartrain and Vicinity, New Orleans, LA, Hurricane Protection Project, T-Wall Repair 17th Street Canal Floodwall Breach is amended as follows: The proposal due date is extended. The new proposal due date is scheduled for 6 February 2006, 1:00 p.m., local time.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 03-Feb-2006	

EXCEPTION TO SF 30
APPROVED BY OIRM 11-84

30-105-04

STANDARD FORM 30 (Rev. 10-83)
Prescribed by GSA
FAR (48 CFR) 53.243

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

CHANGES TO THE SPECIFICATIONS:

Perform the following changes to the plans and specifications:

1. Specifications.

Section 01100, GENERAL PROVISIONS

(a) Section 01100, paragraph 24. SPECIAL WORK REQUIREMENTS. Insert the following new sub-paragraph "e."

"e. The Contractor shall, at his own cost, control any seepage from the breach area within the project limits, during the progress of the work, such that it does not enter the surrounding neighborhoods. The Contractor shall utilize sumps, ditches, sandbags, and pumps as required. Flow shall not be routed to existing catch basins, but shall be collected and pumped directly back into the canal. Erosion control measures shall be provided where necessary."

2. Contract Drawings. Make the following pen and ink changes.

(a) Drawing 7 of 26. In quadrant B – 2/3, I-WALL REPAIR – DETAIL (1).

(1) Revise the text from "REMOVE 36" u x 40'-0" PIPE SECTION" to "REMOVE 36" u PIPE SECTION, 3/8" PLATE (WELDED TO PIPE) AND CONCRETE INCASED AZ SHEET PILE, FROM TOP OF CONCRETE I-WALL TO 6 INCHES BELOW BOTTOM OF I-WALL REPAIR."

(2) Delete text "REMOVE PL 3/8" FROM 6" BELOW TOP OF EXIST. SHEET PILE TO TOP OF CONC. I-WALL (WELDED TO PIPE), in its entirety.