

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE J	PAGE OF PAGES 1   3
2. AMENDMENT/MODIFICATION NO. 0004	3. EFFECTIVE DATE 19-Jan-2006	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO.(If applicable) OEB9 - FOLEY	
6. ISSUED BY USACE, CONTRACTING DIVISION ATTN: CEMVN-CT, ROOM 172 7400 LEAKE AVE. NEW ORLEANS LA 70118-3651	CODE W912P8	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W912P8-06-R-0095	
		X	9B. DATED (SEE ITEM 11) 16-Jan-2006	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The above solicitation for Lake Pontchartrain, Louisiana and Vicinity, New Orleans Area Plan Emergency Restoration, Interim Closure Structure 17th Canal, Orleans Parish, Louisiana is amended as set forth on page 2.  The Hour and Date specified for receipt of Proposals remains unchanged.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		19-Jan-2006

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

The following items are applicable to this modification:

1. Add the following sentence to the end of spec section 15200-1.6.2 "Hydrostatic testing of pipe is not required. "

2. Delete spec section 15200-2.1.1 in its entirety and replace with the following

**"2.1.1 Steel Pipe**

Steel pipe and elbows shall be fabricated in accordance with the requirements of AWWA C200, except hydrostatic testing is not required. Steel used to fabricate pipe shall be any of the specifications listed in Table 1 of AWWA C200, except the minimum yield point shall be 50,000 pounds per square inch or greater. Pipe shall not be helical or spiral seamed. Discharge pipes shall be supplied in lengths equal the width of the Sheet pile cell plus twenty-four (24) inches extending from each side of the sheet pile cell"

3. Delete spec section 15200-2.2 in its entirety and replace with the following

**2.2 PIPE FABRICATION**

The Contractor shall fabricate pipe in accordance with AWWA C200 except the hydrostatic testing requirement is waived. Weld shall be performed and inspected as specified in accordance with Section 05093-3.2. Pipe shall be shipped to site in one piece with flanges attached (on each side, flood and protected). Field welding shall not be performed. Lifting lugs shall be attached for handling and installation. Lifting lugs may be left in place.

4.) Item 0015 on the bid schedule indicates 12 ea Needle Gates. However, only 11 are indicated on the drawings.

Clarification: The bid sheet is correct, there should be 12 Needle Gates, 11 for the structure and one spare.

5.) Should the granular fill placed inside the sheet pile cells located on the west side of the project be placed in Item 0019 - Sheet Pile Cells or Item 0005 - Granular Fill? And the stone surfacing?

Clarification: Section 02413-1.3.5 states "Payment for excavation within cells and connecting arcs, and granular fill is specified in Section 02200 "EARTHWORK".

6.) Spec. Section 03308-1.6.3.2

Is Limestone Powder required to be used in the formulation of the tremie mix?

Is Silica Fume required to be used in the formulation of the tremie mix?

Delete the note at the end of TABLE 1, Section 03308-29 and replace with the following revised note:

**NOTE:** The estimated tremie concrete mixture proportions presented in the table are based on a preliminary mixture design and initial trial batch testing. The mixture proportions are primarily for estimating the bid price of the contract. The actual tremie concrete design will be provided to the Contractor by the Government. Alternatively, the Contractor may propose a concrete mixture design to be used for the tremie concrete. Silica Fume and Limestone Powder are not requirements provided the mix meets the criteria for slump, strength and the other parameters listed in paragraph 1.6.3.2.

END OF INFORMATION

END OF INFORMATION