

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				I. CONTRACT ID CODE J	PAGE OF PAGES 1   2	
2. AMENDMENT/MODIFICATION NO. 0003		3. EFFECTIVE DATE 22-Feb-2006	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) OEB-13, FOLEY	
6. ISSUED BY USACE, CONTRACTING DIVISION ATTN: CEMVN-CT, ROOM 172 7400 LEAKE AVE. NEW ORLEANS LA 70118-3651		CODE W912P8	7. ADMINISTERED BY (If other than item 6)  <b>See Item 6</b>		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X	9A. AMENDMENT OF SOLICITATION NO. W912P8-06-R-0112	
				X	9B. DATED (SEE ITEM 11) 17-Feb-2006	
					10A. MOD. OF CONTRACT/ORDER NO.	
					10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE				
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended.						
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The above solicitation for Lake Pontchartrain and Vicinity, New Orleans Plan, Emergency Restoration, London Ave Canal Levees, Seepage Cutoff, Orleans Parish, LA is amended as follows on PAGE TWO (2)  There is no change to the hour and date specified for receipt of proposals.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
				TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  22-Feb-2006	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**The following items are applicable to this modification:**

Bid Schedule, Section 00010: Change Bid Item 0005 Estimated Quantity from 276,330 to 331,000

Section 01330 Paragraphs 3.7 and 3.8 Add the following to the end of the paragraphs: "In order to expedite review of submittals, an electronic copy of all submittals shall be sent to the Contracting Officer Representative along with the "hard copies". Electronic files shall be in adobe acrobat (pdf), Microstation (dgn), Autocad (dwg), MS Word, or other format acceptable to the Contracting Officer Representative."

Section 02411, Paragraph 3.1.1.2 Add the following to the end of the paragraph: "Piles shall not be driven nor pulled within 100-feet of concrete less than 7 days old nor within 30-feet of concrete less than 28 days."

Section 03307 Paragraph 3.3.3.3, Remove the 4th sentence: "The paving slabs shall be doweled together with ¾-inch diameter smooth dowels, spaced at 18-inch centers."

Dwg 11: On the EXPANSION JOINT Detail, Change "WOOD EXPANSION JOINT FILLER" to "PREMOLDED JOINT FILLER"

END OF CHANGES