

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 7
2. AMENDMENT/MODIFICATION NO. 0003	3. EFFECTIVE DATE 25-Sep-2006	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) ED-99-044
6. ISSUED BY USACE, CONTRACTING DIVISION ATTN: CEMVN-CT, ROOM 172 7400 LEAKE AVE. NEW ORLEANS LA 70118-3651	CODE W912P8	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W912P8-06-R-0159	
		X	9B. DATED (SEE ITEM 11) 21-Aug-2006	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The above numbered solicitation for Southeast Louisiana Urban Flood Control Project to Soniat Canal, Veterans Boulevard to Canal No. 3 Drainage Capital Improvements, Jefferson Parish, LA is amended as follows: BID OPENING DATE OF 05 OCTOBER 2006, 2:00 P.M., LOCAL TIME AND PLACE OF BID OPENING IS ESTABLISHED SPECIFICATIONS CHANGES (SEE CONTINUATION PAGES)				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 25-Sep-2006

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

The following items are applicable to this modification:

SECTION 00010

Delete page 000010-3 in its entirety and substitute the attached revised page 00010-3 therefore.

SECTION 00700

Page 14, provision 52.211-12 LIQUIDATED DAMAGES--CONSTRUCTION (SEP 2000). Change "\$1,285.00" to \$1,925.00".

SECTION 02221

Page 2, paragraph 3.2.1. In the 2nd sentence change "be cut off" to "remain".

SECTION 02242

1. Page 3, subparagraph 1.5(5). Delete this subparagraph in its entirety and substitute the following therefore:

"(5) If the Contractor elects to construct Monoliths 11 and 12 concurrent with other flume monolith construction, an impoundment area in the Soniat Canal will be created between the downstream dam at Monolith 12 and the upstream dam for the other flume construction. The contractor shall be responsible for maintaining the impounded water in the Soniat Canal between his dams at elevation 8.5 feet +/- 0.5 feet Cairo Datum."

2. Page 1, paragraph 1.2.1. Delete this subparagraph in its entirety and substitute the following therefore:

"1.2.1 Construction Dewatering

No measurement will be made for dewatering. Payment for dewatering will be made at the contract lump sum price for "Construction Dewatering". Price and payment shall constitute full compensation for furnishing all plant, labor, material, and equipments; designing, furnishing, installing, maintaining, operating, flooding, rewatering, and removing the dewatering facilities; maintaining the dewatered area; installing and maintaining stream gages; all work incidental thereto including construction of dikes, sumps, maintaining protection dikes and closure dams, protection of slopes, and all other work which may be necessary to accomplish the specified dewatering results and which is not specified to be paid for separately."

3. Page 7, paragraph 3.4.1. Delete this paragraph in its entirety and substitute the following therefore:

“3.4.1 Requirements

Temporary dams shall be constructed of earthen material to an EL. 11 ft CD plus or minus 3/10 of a foot tolerance. Dam material above EL. 6.0 CD shall be a granular material that erodes quickly when the dam is overtopped. The floodside slope may be sealed with a layer of impermeable native material (2 foot maximum thickness) to control seepage. The Contractor shall not be allowed to seal the crown surface of the dam. Staff gages shall be installed outside of the cofferdam area to monitor the water level of the canal. If directed by the Contracting Officer, the dam shall be opened to allow the water through. All water shall be pumped to the north (downstream). If the water level continues to rise then all obstructions in the canal shall be completely removed to allow the canal to flow unimpeded. The cross-section for the earthen dam shall be as designed by the Contractor and maintained for the safety of workers and inspectors. The temporary dams shall be located within 25 feet of the braced excavation unless otherwise specifically shown on the drawings or required for construction. In addition, drainage from streets and yard drains shall be maintained by the Contractor. The Contractor shall provide pipes and pumps to maintain and to provide for area minor drainage during construction. If the Contractor elects to construct Monoliths 11 and 12 concurrent with other flume monolith construction, an impoundment area in the Soniat Canal will be created between the downstream dam at Monolith 12 and the upstream dam for the other flume construction. The contractor shall be responsible for maintaining the impounded water in the Soniat Canal between his dams at elevation 8.5 feet +/- 0.5 feet Cairo Datum.”

4. Page 8, paragraph 3.4.2.1. Change the last sentence to read "Replacement of dams shall not be attempted until Jefferson Parish Pumping Stations have completed pumping operations and the flow in the canal has ceased and until approval is given by the Contracting Officer."

SECTION 02252

1. Page 2, paragraph 1.4.2. Change "(-) 32.3 feet C.D." to "(-) 46.0 feet C.D."
2. Page 7, paragraph 3.3.1. Delete this paragraph in its entirety and substitute the following therefore:

“3.3.1 Removal Criteria

Should the Contractor elect to remove the temporary retaining structures, they shall not be removed until suitable backfill, between the finished structure and the steel sheet pile wall of the temporary retaining structures is satisfactorily placed and

compacted to an elevation approximately one (1') foot below the finished surface. Piles shall not be pulled within 100-feet of concrete less than 7 days old. The temporary retaining structures

shall not be removed until the completed permanent structure and/or excavations are rewatered in the sections of the canal where U-shaped flumes are to be installed (Monoliths 11-12, 58-63, and 71-84). In the areas of the sloped paving, Monoliths 85W and 85-93, the temporary retaining structures shall not be removed until at least 28 days after the vertical wall in the composite section has been constructed.

3.3.1.1 Sheet Piling

For the sheet piles that are to remain in place, as designated on the plans, the sheet piles shall be cut off approximately three feet below the finished grade.

3.3.1.2 Voids

When voids are induced by removal operations, the Contractor shall pump out all seepage and rainwater and backfill to within 3 feet of the ground surface with a tremie-placed slurry. The upper 3 feet shall be filled with backfill. Backfill and compaction requirements shall be as defined in Section 02332 - "EMBANKMENT". All Contractor-furnished temporary retaining structures which are removed shall be hauled from the site upon completion of work."

3. Insert the attached Soil Boring Log for Boring B-3(1993) to the end of this section.

SECTION 02413

Page 5, paragraph 2.1.1. Change the nominal sheet pile thickness in the table from "0.40" to "0.30".

DRAWINGS

1. Dwg. 8 of 48, Quadrant B5, NOTE 13 under the GENERAL NOTES. Change "FIFTY" to "67 1/2".
2. Dwg. 9 of 48, NOTE 6. To the end of this note, add "(MONOLITHS 70-81 and 82W85W)".
3. Dwg. 10 of 48.
 - a. Quadrant D4. Delete the reference "STEEL SHEET PILING (TO BE REMOVED)" and replace with "STEEL SHEET PILING (TO BE CUT-OFF)".
 - b. Quadrant C5. Delete the reference "STEEL SHEET PILING (TO BE REMOVED)" and replace with "STEEL SHEET PILING (TO BE CUT-OFF)".
4. Dwg. 24 of 48.

a. Quadrant C4. Delete the reference "REMOVE SHEET PILING" and replace with "CUT-OFF SHEET PILING" (in two places).

b. Quadrant C4. In the reference, change the length in reference "PILES (L=50' EA)(TYP.)" to "PILES (L=70' EA)(TYP.)"

5. Dwg. 27 of 48, CANAL NO. 3, 36" D.I. AERIAL CROSSING @ 28+00 "A". Change the length in reference "PILE LENGTH = 50FT (TYP.)" to "PILE LENGTH = 70FT (TYP.)"

SECTION 00010 - BIDDING SCHEDULE

Southeast Louisiana Urban Flood Control Project
 Improvements to Soniat Canal, Veterans Boulevard to Canal No. 3
 Drainage Capital Improvements
 Jefferson Parish, Louisiana

Item	DESCRIPTION	Estimated Quantity	Unit	Unit Price	Estimated Amount
0001	Mobilization and Demobilization	1	LS		
0002	Work Platform	1	LS		
0003	Traffic Control and Coordination	1	LS		
0004	Truck Wash-Down Racks	1	LS		
0005	Geotextile	29,500	SY		
0006	Selective Demolition	1	LS		
0007	Construction Dewatering	1	LS		
0008	Temporary Dam Emergency Removal and Reconstruction	48	EA		
0009	Temporary Retaining Structures	1	LS		
0010	Rip Rap	40	TON		
0011	Canal Excavation	49,250	CY		
0012	Accumulated Sand Removal	5,000	CY		
0013	Canal Bank Grading	1	LS		
0014	Granular Backfill Material	1	LS		
0015	Embankment	1	LS		
0016	Utility Pile Bents	1	LS		
0017	Bedding Material	21,700	CY		
0018*	Vinyl Sheet Piling	1,090	SF		
0019	36" Waterline Relocation	1	EA		
0020	Reinforced Concrete Drain Pipe (15")	56	LF		
0021	Reinforced Concrete Drain Pipe (24")	65	LF		
0022	Reinforced Concrete Drain Pipe (36")	12	LF		

* Denotes a change from previous Bidding Schedule

00010-3

LOG OF BORING AND TEST RESULTS
 JEFFERSON PARISH, IMPROVEMENTS TO CANAL NO. 3
 BETWEEN I-10 AND SONIAT CANAL, JEFFERSON PARISH, LOUISIANA

(SHEET 1 of 1)



Scale In Feet	Ground Elev.:	SPT	Datum: S P L R	Visual Classification	USC	Sample Number	Depth In Feet	Water Content Percent	Density		Shear Tests			Atterberg Limits			Other Tests
									Dry	Wet	Type	Ø	C	LL	PL	PI	
						1	0-0.5										
				Medium compact gray clayey silt w/grass	ML	2	2-3	57	59	92	UC	--	785				
				Medium stiff dark gray silty clay w/clayey silt layers & roots	CL	3	5-6	37	78	107	UC	--	795				
	0.50			Medium stiff dark gray & brown silty clay w/roots	CH	4	8-9	81	50	90	UC	--	250				
	0.25			Soft dark gray clay w/humus layers & decayed roots	OH	5	11-12	203	26	77	UC	--	435				
	0.25			Soft gray clay w/clayey silt lenses & trace of organic matter	CH	6	14-15	77	54	97	UC	--	295				
	0.15			Soft gray clay w/clayey silt lenses	CH	7	18-19										
	0.15					8	23-24	56	67	104	UC	--	350				
	0.20					9	28-29										
	0.25					10	33-34	57	66	103	UC	--	375				
	0.25					11	38-39										

Refer To "Legends & Notes"