

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 21-Oct-2006	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY USACE, CONTRACTING DIVISION ATTN: CEMVN-CT, ROOM 172 7400 LEAKE AVE. NEW ORLEANS LA 70118-3651	CODE W912P8	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W912P8-06-R-0233	
		X	9B. DATED (SEE ITEM 11) 30-Sep-2006	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The above numbered solicitation for Federal and Non-Federal Pump Stations, Flood Control, Plaquemines Parish, LA, Rehabilitation of Plaquemines Parish Pump Stations, Design-Build Services, Plaquemines Parish, LA is hereby amended as follows: See additional pages for Answers to Questions, the Past Performance Questionnaire and Drawing 6. PROPOSAL DUE DATE REMAINS THE SAME - 30 OCTOBER 2006				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 21-Oct-2006

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

Item 1) Reference Section 00110, par 2; should SF 1442 and offeror's guarantee be submitted with Phase I proposals? If yes what are we to guarantee if no price is submitted in Phase I? **Bid bonds are required in Phase II.**

Item 2) Reference Section 00110, par 5.1.1; states that 11" x 17" sheets will be counted as 4 pages for single – sided and 2 pages for double – sided pages. Is this correct? **Yes, it is correct.**

Item 3) Please provide a sample Past Performance Evaluation Questionnaire and Transmittal Letter as described in 00100 9.1.6. **Past Performance Questionnaire is provided in this amendment. Official company letterhead should be used for the transmittal letter.**

Item 4) Confirm that the Past Performance Evaluation Questionnaire forms are to be returned directly to the Corps of Engineers and not submitted with the Proposal. **The Past Performance Evaluation Questionnaire and Transmittal Letters are to returned directly to the US Army Corps of Engineers as per the instructions provided in Section 00110, 'Proposal Submission Requirements', page 7, paragraph 9.1.1.6.**

Item 5) Reference Section 00110, par 9.1.2.1, wherein it states that experience with design, construction, and installation of similar size and scope for heating and cooling requirements of this project are considered relevant. The work as evident by the bid items has very little work involved with heating and cooling. Is this work of that much of importance to make it a factor? **The referenced paragraph, Section 00110, 'Proposal Submission Requirements', page 7, paragraph 9.1.2.1, sentence number 3, should state 'Experience with the design, construction and installation of similar size and scope for mechanically drive pump requirements of this project are considered relevant.'**

Item 6) Is the review time for the Government specified in Section 01120, par 1.6 in calendar days? **The review times for the Government specified in Section 01120, Design Requirements, paragraph 1.3, statements 1-7, are in calendar days.**

Item 7) Section 01110, par 3.1.2 notes five (5) items that are a part of this solicitation. Only item no. 1 was provided. Please provide item nos. 2 through 5. **Item Number 2 (Solicitation Drawings) of Section 01110, 'Summary of Work' paragraph 3.1.2., was made available as part of amendment Number 1 to this solicitation, dated 09 October 2006. Items Number 3-5 (Geotechnical Investigation, Pump Station Nameplate and Performance Report, Record Drawings and Specifications and Additional Damage Photographs) are incidental to the project and will be made available at the Pre-Bid Conference during the Phase II Evaluation Process. These items are not available for view at the moment and have not been viewed by any potential offerors.**

Item 8) Section 00110, par 11, page 20; will Offerors be reimbursed for the cost of preparing their proposals for Phase II, Volume II? **Offerors will not be reimbursed for the cost of preparing their Phase II, Volume II proposals.**

Item 9) What is the time frame for the Government's review of Phase I proposals along with selecting and notifying the Offerors to participate in Phase II? **The time frame for the Government's review of Phase I proposals along with the selection and notification of Offerors to participate in Phase II can not be determined until Phase I submission is closed as this time frame will be dependent on the number of submittals received. The duration that will be given to Offerors for preparing Phase II proposals will be 30 days.**

QUESTION AND ANSWER SET #2

- 1.) Specification section 001100 9.1.3.1 lists the minimum Key Personnel Resumes required. In specification section 00120 detailed evaluation criteria 4.1.3 a landscape architect and site manager are listed as evaluation factors but are not listed in section 001100 9.1.3.1. Are resumes for the landscape architect and site manager required for this solicitation? **The resume requirements specified in Section 00120, 'Proposal Evaluation Criteria', page 5, paragraph 4.1.3 for the landscape architect and site manager shall be deleted from the solicitation. This paragraph should parallel the proposal criteria as specified in section 00110, 'Proposal Submission Requirements', page 9, paragraph 9.1.3.1.**
- 2.) Specification section 00110 9.1.1.5.1 Can the incident rates for the past three years be presented on one page instead of a page for each year? **The incident rates for the past three years shall be presented on separate sheets as specified in section 00110, 'Proposal Submission Requirements', pages 6-7, paragraph 9.1.1.5.1.**
- 3.) Specification section 00110 9.1.4.1.6 How can we identify the percentage of work to be self performed if a cost has not been associated with the project? Can historical data be used instead? **Because price proposals will not be submitted until the request for Phase 2 submittals, for the purpose of Phase 1 submittals, the percentage of work to be self performed, as required in Section 00110, 'Proposal Submission Requirements', page 11, paragraph 9.1.4.6 can be identified based on historical data and offeror's estimates.**
- 4.) Drawings 6 of 70 is missing from Amendment No. 0001 please provide. **This drawing is being provided in this amendment.**

(End of Summary of Changes)

COMPANY SPECIALIZED EXPERIENCE

Provide the following information to show examples of projects your company constructed within the boundaries of the Mississippi Valley Region over the last three years indicating experience with projects similar type and scope. Use separate sheets.

- a. Your Firm's Name: _____
- b. Name of Project: _____
- c. Location of Project: _____
- d. Name of Customer: _____
- e. General Scope of Project: _____



- f. Professional qualifications (Surveyors, Cost Estimators, etc.) _____

- g. Your Firm's Role (Prime, Joint Venture, or Subcontractor, etc.) and Work your Firm performed _____

- h. Construction Cost: (1) Overall Project: _____
(2) Your Portion of Project: _____
- i. Extent and Type of Work you Subcontracted out: _____

- j. Dates Construction: Began: _____ Completed: _____


Safety is a Part
of Your Contract



CONCEPTUAL LAYOUT OF
REQUIRED ENGINE BUILDING

NOTES

1. REMOVE AND REPLACE EXISTING CHAIN LINK FENCE.
2. INSTALL NEW DOUBLE GATE.
3. CONSTRUCT NEW TRASH RACKS AT LOCATION SHOWN.
4. REMOVE AND REPLACE EXISTING FUEL TANK AND FOUNDATION. OLD TANK TO BE ABANDONED. PROVIDE GRAVITY FEED TO NEW DAY TANK.
5. PROVIDE ABOVE GROUND DAY TANK AND FOUNDATION. MATCH EXISTING TANK SIZE.
6. REMOVE DEBRIS FROM TOE OF LEVEE TO CANAL BANK BETWEEN FENCES.
7. ALL ELEVATIONS ARE REFERENCED TO AN ASSUMED DATUM.
8. REPLACE WINDOWS IN EXISTING PUMPING STATION.
9. PROVIDE A DIESEL GENERATOR SIZED SUFFICIENT TO RUN ALL BUILDING AND EXTERIOR ELECTRICAL SYSTEMS SIMULTANEOUSLY.
10. SOIL BORING B-1. SEE GEOTECHNICAL INVESTIGATION PREPARED BY EUSTIS ENGINEERING.
11. REPLACE DOORS IN EXISTING PUMPING STATION.



LINFIELD, HUNTER & JUNIUS, INC.
CONSULTING ENGINEERS AND ARCHITECTS
3608 18th Street, Suite 200
Metairie, Louisiana 70002

PLAQUEMINES PARISH PUMP STATIONS
BELAIR PUMP STATION
SITE PLAN
FILE NUMBER H-4-46449 DWG: 6 OF 70

U. S. ARMY ENGINEER DISTRICT, NEW ORLEANS CORPS OF ENGINEERS NEW ORLEANS, LOUISIANA			
DESIGNED BY: LHJ	PLOT SCALE: 1	DESIGN FILE NAME: SUBMITTED BY: LINFIELD, HUNTER & JUNIUS, INC. DESIGN ENGINEER	SOLICITATION NO. W912P8-06-R-0233
CHECKED BY: LHJ	PLOT DATE: 09-15-06		
DRAWN BY: LHJ			
DATE:			

MARK	DESCRIPTION	DATE	APPR.	MARK	DESCRIPTION	DATE	APPR.

