

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
			J	1	4
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 11-Dec-2006	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)	
6. ISSUED BY USACE, CONTRACTING DIVISION ATTN: CEMVN-CT, ROOM 172 7400 LEAKE AVE. NEW ORLEANS LA 70118-3651	CODE W912P8	7. ADMINISTERED BY (If other than item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. W912P8-07-B-0023	
			X	9B. DATED (SEE ITEM 11) 03-Nov-2006	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The above numbered solicitation for the IDIQ Supply Contract has been amended as follows: BID OPENING DATE THE BID OPENING DATE OF THURSDAY 14 DECEMBER 2006 11:00 A.M. HAS BEEN CHANGED TO THURSDAY 21 DECEMBER 2006 11:00 A.M. LOCAL TIME AND PLACE OF BID OPENING. All other terms and conditions remain unchanged.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 11-Dec-2006	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SF 33, Block 4, Type of Solicitation, change from Negotiated (RFP) to Sealed Bid (IFB).

Amendment 0001 reads "Please delete Section 00010...". Correct to read "Delete Section B in it's entirety and replace with New Section B".

Replace Note 2 at the end of Section B of Amendment 0001 and replace with the following note:

NOTE 2: All Task Orders shall be issued to the Contractor within 18 months after award and the last delivery shall be made no later than 730 days after award. Upon issuance of the individual Task Orders, materials shall be at the storage location ready for delivery to the designated construction site within 3 months for the steel H-Piles, pipe piles and sheet piles and within 4 months for the precast concrete piles. If painting is required for the steel products, an additional month shall be added to the above time frame.

Delete Section C3, "Steel Sheet Piling" in it's entirety and replace with new attached Section C3.

SECTION C3 - STEEL SHEET PILING

1. SCOPE. The work covered by this section consists of furnishing all plant, equipment, labor and materials and performing all operations in connection with the fabrication, painting, storage, and shipping of steel sheet piling in accordance with these specifications.

2. REFERENCES. The following standards of the issues listed below and referred to thereafter by basic designation only from a part of this specification to the extent indicated by the references thereto:

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

A 572 (2006) High-Strength Low-Alloy Columbium-Vanadium Structural Steel.

3. SUBMITTALS. The Contractor shall submit descriptions of test procedures, test reports, certificates, and other required submittals to the Contracting Officer for approval as required. Submittals and associated work not satisfactory to the Contracting Officer will be rejected.

3.1. Materials Test Certificates. Materials test certificates shall be submitted for each shipment and identified with specific lot. Identification data should include piling type, dimensions, section properties, heat analysis number, chemical composition, mechanical properties and mill identification mark. Piling will be accepted only when the mill certificates are verified and approved. Three (3) copies of certificates shall be submitted.

4. STORAGE AND HANDLING. The manufacturer's logo and mill identification mark shall be provided on the sheet piling as required by the referenced specifications. Sheet piling shall be stored and handled in the manner recommended by the manufacturer to prevent permanent deflection, distortion or damage to the interlocks. Storage of sheet piling should also facilitate required inspection activities.

5. MATERIALS. Steel for sheet piling shall conform to the requirements of ASTM A 572 Grade 50. All sheet piling shall be provided with standard pulling holes located approximately four (4) inches below the top of the pile. Steel sheet piling shall be hot rolled and shall have the properties equivalent to those listed in the following table:

PROPERTIES OF SECTIONS

Type of section	Nominal web thickness (inches)	Section modulus (in ³ /ft of wall)	Moment of inertia (in ⁴ /ft of wall)	Nominal section depth (inches)	Minimum interlock strength (lbs/lin in)	Theoretical driving width (inches)
PZ 22	0.375	18.1	84.4	9	N/A	22
PZ 27	0.375	30.2	184.2	12	N/A	18
PZ 35	0.50	48.5	361.2	15	N/A	22.64

5.1 Substitute Sheet Pile Sections

The Contractor may elect to substitute for the sheet piling specified above, in accordance with paragraph 5.2. Combinations of substitute piling types shall not be permitted.

5.2 Hot Rolled Z-Type Steel Sheet Piling

At no additional cost to the Government, new Z-type hot rolled steel sheet piling conforming to ASTM A 572, Grade 50 and meeting the following section properties and having a minimum web thickness of 0.375 inches, may be substituted in kind for the listed sections:

PROPERTIES OF SECTIONS

Type of Section Called Out on Drawings	Substitute Section	
	Minimal Section Modulus (in ³ /ft of wall)	Minimum Section Depth (inches)
PZ 22	18.1	9
PZ 27	30.2	12
PZ 35	48.5	15

6. SHEET PILING LENGTHS. All sheet piling shall be new and shall be provided in full lengths. The lengths indicated in the Task Order shall be acceptable when within a tolerance of plus or minus one (1) inch.

7. PAINTING. Steel sheet piling shall be painted with coal-tar epoxy in accordance with Section 09940, "PAINTING".