

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
			J	1	2
2. AMENDMENT/MODIFICATION NO. 0004	3. EFFECTIVE DATE 18-Nov-2006	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)	
6. ISSUED BY USACE, CONTRACTING DIVISION ATTN: CEMVN-CT, ROOM 172 7400 LEAKE AVE. NEW ORLEANS LA 70118-3651	CODE W912P8	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. W912P8-07-R-0018	
			X	9B. DATED (SEE ITEM 11) 04-Nov-2006	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE			FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  The above numbered solicitation for acquisition of pumps is hereby amended as follows: See Page 2 for clarifications. NOTE: The due date and time for receipt of proposals remains unchanged.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  18-Nov-2006	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

## Section 1.11 Painting

Replace Paragraph 2, Sentence 1 with:

“The engines, all gear box housings, shafting and all their related accessories shall be furnished with enamel finish.”

## Section 1.12 Tests

Delete Sub-Paragraph 1, Sentence 3: ‘A factory operation test is not required for the drainage pumps.’

Section 1.19.1 17<sup>th</sup> Street Canal

Insert the Asterisk Note Below Table at end of Section with:

“\* ‘Head (ft)’ indicates the Total Dynamic Head but not inclusive of dynamic losses in the FSI or internal to the pump.”

## Section 1.19.2 London Avenue Canal

Replace the Asterisk Note Below Table at end of Section with:

“\* ‘Head (ft)’ indicates the Total Dynamic Head but not inclusive of dynamic losses in the FSI or internal to the pump.”

## Section 2.3.1 Impellor Bowl

Replace Paragraph 1, Sentence 2, phrase ‘Provide flanges for mating...’ with “Provide joints for mating...”

## 2.3.3.1 Column and Discharge Elbow

Replace Paragraph 1, Sentence 5 with:

“Provide flanges for mating the discharge elbow to a flanged expansion joint and for mating the pump column and diffuser bowl. The discharge elbow shall be welded to the pump column.”

## Section 2.18.1 General

Replace Paragraph 9, Sub-Paragraph 24 with:

“Air Cooled Radiator with fan driven by the pump engine.”

## Section 2.18.2 Instruments

Replace Paragraph 1, List Note with:

“See Section 2.37 for Additional Requirements.”

## Section 2.37 Pumping System Control

Replace Paragraph 3 with:

“A single Remote Operator Control Panel shall be provided at the 17<sup>th</sup> Street Canal site and at the London Avenue Canal site (2 total remote control panels). The Remote Operator Control Panel shall be mounted in the existing Operator Control Room and shall be provided for monitor and control of all direct drive pump systems on the site.”

(End of Summary of Changes)