SAFETY INSPECTION FOR MISCELLANEOUS EQUIPMENT U.S. Army Engineer District, New Orleans	Date of Inspection:
Contractor or Unit	Contract No. or Activity
Inspected by (Signature)	Witness (Signature)

	RIGGING AND WIRE ROPE CHECKLIST NOTE: Safety and Health Requirements Manual (EM385-1-1) references in parentheses.	Yes	No	N/A
1	Has all defective rigging as specified in Appendix F been removed from service? (15.A.01)			
2	Is the hoist rope being wrapped around the load? (15.A.02)			
3	Are running lines located within 6'6" of ground or working level guarded? (15.A.03)			
4	When hoisting loads, is a positive latching device used? (15.A.05)			
5	Have hooks, shackles, rings, pads, etc. showing excessive wear or been bent, twisted, or damaged been removed from service? (15.A.06)			
6	When two wires are broken, rusty, or corrosion is found adjacent to a socket or end fitting, is the wire rope removed? (15.B.01) **Note:** Check end fittings on boom support, pendants, guy ropes, etc.)			
7	Is the clip attached to the live wire on wedge sockets? (15.B.04)			
8	Except for eye splices in ends of wire for wire rope slings, is wire rope used in hoisting, lowering, or pulling load one continuous piece without knot or splice? (15.B.07)			
9	Are wire rope clips used to splice wire rope? (15.B.09)			
10	Are only alloyed type chains used in rigging? (15.C.01)			
11	Are hooks, links, or fasteners made from bolts and rods used? (15.C.04)			
12	Is protection provided between the sling and sharp surfaces of the load to be lifted? (15.E.02)			
13	Are open hooks used in rigging to hoist loads? (15.F.07)			
14	Are shoulderless eye bolts loaded at an angle? (15.F.10)			

REMARKS: