

SAFETY INSPECTION FOR CONSTRUCTION ACTIVITY
U.S. Army Engineer District, New Orleans

Date of Inspection:

Contractor or Unit	Contract No. or Activity
Inspected by (Signature)	Witness (Signature)

BUILDING CONSTRUCTION		Yes	No	N/A
NOTE: Safety and Health Requirements Manual (EM385-1-1) references in parentheses.				
1	Is safe access provided to all work areas? (21.A.01)			
2	Are guardrails, intermediate rails, and toe boards installed on ramps, steps, runways, scaffolds, and other working surfaces 6 feet or more in height? (21.B.01 and 30.A.07)			
3	Does the free-standing metal scaffold or tower working platform height exceed 3 times the smallest base dimension? (22.C.06)			
4	Does planking meet the requirements listed in 22.B.06?			
5	Are all planks on metal scaffolds cleated at both ends to prevent movement? (22.B.06)			
6	Are supporting members of scaffolds placed on unstable objects such as barrels, boxes, loose bricks, concrete blocks, etc.? THIS IS A VIOLATION. (22.B)			
7	Do rolling scaffolds have a positive locking device to prevent accidental movement? (22.C.06 (c))			
8	Are rolling scaffolds moved only from the base? (22.C.06 (c))			
9	Are safety nets used where scaffolds, catch platforms, or temporary floors are impractical? (21.C.10)			
10	Have the nets been tested and are they inspected daily? (05.G.01)			
11	Are safety belts and life lines furnished workers on structural steel erection, bins, hoppers, steep slopes, swinging scaffolds, etc? NOTE: Life lines shall be separately attached of attended. (21.C)			
12	Are portable ladders secured top and bottom so as to be stable? (21.D.08 (d))			
13	Do portable ladders have a safe pitch? (21.D.08 (b))			
14	Have guardrails been provided for all floors, roof holes and wall openings 4 feet above adjacent floor? (24.A.01 and 24.A)			
15	Are means provided to prevent tools, materials, etc. from falling when work is performed overhead? (13.A.04)			
16	When welding and torch work is being performed, is protection from arc flashes, slag, and heat provided? (10.A.04)			
17	Are ladders, stairways, & passageways kept clear of hoses, cables, & other equipment? (10.A.05)			
18	Are compressed gas cylinders secured in an upright position? (20.D.10)			
19	Is fire extinguishing equipment provided? (09.E.01-06 & 13.A.06-09 & 14.A.05)			
20	Are provisions made to prevent welding cables from being used near high tension wires? (10.E.08)			
21	Are provisions made to prevent welding leads from contacting metal parts of supporting suspended scaffolds? (10.E.09)			
22	Is welding equipment shutdown when not used or leads are unattended? (10.E.11)			
23	Are circular portable power saws equipped with automatic blade guards? (13.C.01 (a))			
24	Are personal protective devices and equipment provided and their use enforced? (05.A)			
25	Is all welding apparatus and equipment being inspected daily? (10.A.02 & 10.D.04)			
26	Are all fuel gas-oxygen units used in welding or cutting operations equipped with reverse-flow check valves installed between torch and hoses? (10.D.07 (b))			

27	Are oxygen/acetylene units permitted to be used with the acetylene regulator adjusted to permit a discharge of greater than 15 psig? (10.D.12) THIS IS A VIOLATION.			
28	Are safety lashings provided at quick make up connections between tool and hoses when using pressurized equipment? (20.A.16)			
29	Do manually operated air tools with flexible hoses have an automatic shut-off valve to prevent whipping and lashing? (20.A.15)			
30	Is the temporary wiring guarded, elevated, buried, or isolated so as to prevent contact? (11.D)			
31	Are wire guards provided for light bulbs? (11.O.06)			
32	Are all 120 volt, single phase, 15 & 20 ampere, receptacle outlet circuits which are not a part of the building's permanent wiring provided with ground fault circuit interrupters for personnel protection? (11.C.05)			
33	Are all flood and/or work lights grounded? (11.C.01 (c))			
34	Is a signal person provided when work area is hidden from equipment operators? (08.B.03)			
35	Are crawling boards, life lines, temporary decking, etc. furnished to prevent workmen on roofs from falling? (27.H.01)			
36	Is hoist lift or other approved means used to raise materials and tools to roofs over 16 feet high? (27.H.02)			

REMARKS:
